



VADODARA MUNICIPAL CORPORATION

PUBLIC HEALTH LABORATORY

Vadodara - 390 002, Phone : 0265 - 27 81 433

REPORT ON SHORT PHYSICAL & CHEMICAL EXAMINATION OF WATER

To, NAVRACHANA VIDYANI VIDYALAYA
NEAR SAMA SPORTS COMPLEX NEW SAMA ROAD
VADODARA

Test Report No. : PHL/PW/455/2023
Date : 16/5/2023
Date of Collection : 10/5/2023
Sample No. : PW/455/2023

Source and Details of Sample : R.O. Water

Sr. No.	Characterisitic	Analytical Value	Permissible Value as per IS : 10500 : 2012	
			Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
1.	Colour, Hazen Unit, Max	Colourless	5	15
2.	Odour	Agreeable	Agreeable	Agreeable
3.	Turbidity NTU, max	Nil	1	5
4.	pH Value	8.40	6.5 - 8.5	6.5 - 8.5
5.	Total Alkalinity (as CaCO ₃), mg/L, Max	48	200	600
6.	Total Hardness (as CaCO ₃), Mg/L, Max	14.0	200	600
7.	Calcium (as Ca), mg/L, Max	3.0	75	200
8.	Magnesium (as Mg), mg/L, Max	1.4	30	100
9.	Chloride (as Cl), mg/L, Max	22.0	250	1000
10.	Sulphate (as SO ₄), mg/L, Max	Nil	200	400
11.	Nitrate (as NO ₃), mg/L, Max	----	45	45
12.	Fluoride (as F), mg/L, Max	Nil	1.0	1.5
13.	Total Dissolved Solids mg/L, Max	86.0	500	2000
14.	Mineral oil mg/L, Max	----	0.5	0.5
15.	Ammonia (Sewage Contamination)	Absent	Absent	Absent
16.	Free Residual Chlorine mg/L, Min	----	0.2	1.0

Remark : (For Sr. No. : 16) to be applicable only when water is chlorinated. Tested at consumer end. When protection against viral infection is required, it should be minimum 0.5 mg/l

Opinion : The Water is Chemically Fit for Drinking Purpose.

BACTERIOLOGICAL QUALITY NAVRACHANA VIDYANI VIDYALAYA

Sr. No.	Organisms	Result	Requirements as per IS: 10500:2012
1	E, Coli	Absent	shall not be detectable in any 100 ml sample

Opinion : The Water is Bacteriologically Fit for Drinking Purpose.

Self Attested

Navrachana Vidyani Vidyalaya

NOTE : The Sample was Not Drawn by this Office
Sr. Manager (A/Cs & Admin)



Food Analyst
Vadodara Municipal Corporation
Vadodara

NAVRACHANA VIDYANI VIDYALAYA
SAMA ROAD, VADODARA
PRINCIPAL



VADODARA MUNICIPAL CORPORATION

PUBLIC HEALTH LABORATORY

Vadodara - 390 002, Phone : 0265 - 27 81 433

REPORT ON SHORT PHYSICAL & CHEMICAL EXAMINATION OF WATER

To, NAVRACHANA VIDYANI VIDYALAYA
NEAR SAMA SPORTS COMPLEX NEW SAMA ROAD
VADODARA

Test Report No. : PHL/PW/457/2023

Date : 16/5/2023

Date of Collection : 10/5/2023

Sample No. : PW/456/2023

Source and Details of Sample : Tap Water

Sr. No.	Characterisitic	Analytical Value	Permissible Value as per IS : 10500 : 2012	
			Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
1.	Colour, Hazen Unit, Max	Colourless	5	15
2.	Odour	Agreeable	Agreeable	Agreeable
3.	Turbidity NTU, max	0.24	1	5
4.	pH Value	8.50	6.5 - 8.5	6.5 - 8.5
5.	Total Alkalinity (as CaCO ₃), mg/L, Max	432	200	600
6.	Total Hardness (as CaCO ₃), Mg/L, Max	218	200	600
7.	Calcium (as Ca), mg/L, Max	50.0	75	200
8.	Magnesium (as Mg), mg/L, Max	23.0	30	100
9.	Chloride (as Cl), mg/L, Max	122	250	1000
10.	Sulphate (as SO ₄), mg/L, Max	85.0	200	400
11.	Nitrate (as NO ₃), mg/L, Max	----	45	45
12.	Fluoride (as F), mg/L, Max	0.92	1.0	1.5
13.	Total Dissolved Solids mg/L, Max	616	500	2000
14.	Mineral oil mg/L, Max	----	0.5	0.5
15.	Ammonia (Sewage Contamination)	Absent	Absent	Absent
16.	Free Residual Chlorine mg/L, Min	----	0.2	1.0

Remark : (For Sr. No. : 16) to be applicable only when water is chlorinated. Tested at consumer end. When protection against viral infection is required, it should be minimum 0.5 mg/l

Opinion : The Water is Chemically Fit for Drinking Purpose.

BACTERIOLOGICAL QUALITY

Sr. No.	Organisms	Result	Requirements as per IS:10500:2012
1	E, Coli	Absent	shall not be detectable in any 100 ml sample

Opinion : The Water is Bacteriologically Fit for Drinking Purpose.

Self Attested

Navrachana Vidyan Vidyalaya

NOTE : The Sample was not Drawn by this Office

Sr. Manager (A/Cs & Admin)



Food Analyst
Vadodara Municipal Corporation
Vadodara

PRINCIPAL
NAVRACHANA VIDYANI VIDYALAYA
SAMA ROAD, VADODARA.