



cfo@vmc.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOVMC/2025/00111733

Date: 26/06/2025

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOVMC/2025/00111733/R1

Building Occupancy/Category: Educational (non-residential)

To,

Kiransinh Chauhan

- NEAR SAMA SPORT COMPLEX SAMA VADODARA Vadodara MC 390008

Fire Region: Vadodara MC

Mobile No: 8849084511 Email ID: kiransinh64@gmail.com

We have received Application No. 2025/00125721 dated 06/06/2025 for Fire Safety Certificate Renewal (FSCR) - New Building(FSCR)/Existing Building (FSCRe) for the building/premise NAVRACHANA VIDYANI VIDYALAYA (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: VADODARA
5. Name of Block(s): NAVRACHANA VIDYANI VIDYALAYA BLOCK A B , NAVRACHANA VIDYANI VIDYALAYA BLOCK C D

The building/premise was inspected on 26/06/2025 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 26/06/2025
2. Six monthly inspection was done on 26/06/2025

The Fire Safety Certificate is renewed for a period of **two (2)** years upto 26/06/2027 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated: 26/06/2025 11:03:57 AM

Navrachana Vidayani Vidyalaya

Sr. Manager (O&A) Adm.



Digitally Verified

Digitally verified by: Milind Surendra Ranade

Fire Safety Officer - Advance (FSO-A)

2021/000004

Reviewed by : CFO Vadodara MC

Date: 26/06/2025

Time: 11:34 AM

PRINCIPAL

NAVRACHANA VIDYANI VIDYALAYA
SAMA-VADODARA

FSCA/O/CFOVMC/2025/00111733/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.